

**Wastewater Treatment Plant Upgrade Project  
City Project No. 2018-01  
March 22, 2018**

**DESIGNER**

HDR Engineering, Inc.  
2365 Iron Point Road, Suite 300  
Folsom, CA 95630  
(916) 817-4700  
(916) 817-4747 (Fax)

**OWNER**

Fort Bragg  
Municipal Improvement District No. 1  
416 North Franklin Street  
Fort Bragg, CA 95437



03/22/18

**GENERAL**

**Scope**

- A. This Addendum forms a part of the Bidding and Contract Documents and modifies the Project Specifications and Drawings described below.
- B. This Addendum consists of 4 pages.

**Acknowledgment**

- A. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

## **REVISIONS TO SPECIFICATIONS**

### ***Table of Contents***

#### **Article 00480 Title**

##### **CHANGE TO READ**

"List of Subcontractors"

### ***Section 00100 – Advertisement for Bids***

#### **Paragraph 1 on Page 00100-1**

##### **CHANGE TO READ**

"Sealed Bids for the construction of the Wastewater Treatment Plant Upgrade Project will be received by City of Fort Bragg at the office of 416 North Franklin Street, Fort Bragg CA, 95437 until 2:00 PM local time on **Tuesday, April 17, 2018**, at which time the Bids will be publicly opened and read. The Project consists of constructing upgrading and modifying existing wastewater treatment plant."

#### **Paragraph 6 on Page 00100-1**

##### **CHANGE TO READ**

"A pre-bid conference will be held at 9:00 AM local time on **Thursday, March 29, 2018**, **Fort Bragg Town Hall** located at 363 North Main Street, Fort Bragg, CA 95437. Attendance at the pre-bid conference is mandatory."

### ***Section 00520 - Agreement***

#### **Footer on all pages of section**

##### **CHANGE TO READ**

"00520-#"

### ***Section 00800 - Supplementary Conditions***

#### **Article SC-1.01 Defined Terms**

##### **First two paragraphs**

##### **DELETE**

#### **Article 5, Sub-paragraph SC/GBR-5.03 A.1.a.**

##### **CHANGE TO READ**

"a. Report dated [February 19, 2016, prepared by Edwin P. Woo, P.E., G.E., HDR entitled: "Geotechnical Investigation Report (GIR) - Fort Bragg Wastewater Treatment Plant Upgrade Project", consisting of 36 pages.] The technical Data contained in such report upon whose accuracy Contractor may rely are those indicated in the definition of Technical Data in the General Conditions.

## **Article 5, Sub-paragraph SC/GBR-5.04 A.1.**

### **CHANGE TO READ**

"1. Differs materially from conditions shown or indicated in the GIR; or"

## **Article 5, Sub-paragraph SC/GBR-5.04 A.2. and A.3.**

### **DELETE**

## **Article 5, Sub-paragraph SC/GBR-5.04 A.4., A.5. and A.6.**

### **CHANGE TO READ**

- "4. to the extent the GIR is inapplicable, is of such a nature as to establish that any Technical Data on which Contractor is entitled to rely as provided in Paragraph 5.03 is materially inaccurate; or
5. to the extent the GIR is inapplicable, is of such a nature as to require a change in the Drawings or Specifications; or
6. to the extent the GIR is inapplicable, is of an unusual nature, and differs materially from conditions ordinarily encounters and generally recognized as inherent in work of the character provided for in the contract Documents;"

## **Article SC-19.10 E. Special Condition 8, 9, and 10**

### **DELETE**

## ***Section 01 45 25 - Testing Concrete Structures and Watertightness***

### **Article 1.2 C.**

#### **CHANGE TO READ**

"C. Contractor shall test all new precast or cast-in-place, water bearing structures without exceptions.

## ***Section 26 32 14 - Engine Generator: Diesel***

### **Article 2.1 A.1.**

#### **CHANGE TO READ**

- "1. Engine generator unit:
- a. Caterpillar.
  - b. Cummins Onan.
  - c. Kohler.
  - d. Generac.
  - e. MTU Onsite Energy.
  - f. Or approved equal."

## ***Section 31 23 00 - Earthwork***

### **Article 1.1 A.**

#### **ADD**

"2. Soil boring information from Geotechnical Investigation Report (GIR) are included at the end of this section."

**Article 3.6 B. 7.a.**

**CHANGE TO READ**

"a. Groundwater will be encountered during excavation. Install a dewatering system to prevent softening and disturbance of subgrade below foundations and fill material, to allow foundations and fill material to be placed in the dry, and to maintain a stable excavation side slope."

**End of Addendum**